

Fire Department

Fire Chief Larry Horton
A Shift Captain – Hunter Knight
B Shift Captain – Barry Wright
C Shift Captain – Eric Littleton

Moody Fire & Rescue

Pre-Inspection Checklist

911 Fire Fighter Blvd
Station 1

Mayor Joe Lee

Council

Linda Crow
Lynn Taylor
Matt Morris
Nick Rutledge
Ellis Key

A. Exits

| | |
|---------------------------------------------------------------|------------------------------------|
| Door/aisle is not obstructed | International Fire Code 1003.6 |
| Proper lock/hardware on exit door | International Fire Code 1008.1.8.4 |
| Exit doors open easily | International Fire Code 1008.1.8 |
| Right of entry (permission to enter) | International Fire Code 104.3 |
| Means of egress shall be kept clear | International Fire Code 806.1.3 |
| Illuminated exit signs maintained and in working order | International Fire Code 1011.2 |
| Doors with panic hardware shall have no other locking devices | International Fire Code 1008.1.9 |

B. Extinguishers/Fire Protection Equipment

| | |
|-----------------------------------------------------------------------------|------------------------------------|
| Minimum 2A10BC extinguishers installed | International Fire Code 906.3 |
| Extinguisher has been serviced within the past year | International Fire Code 906.2 |
| Extinguisher is securely mounted or in an approved cabinet | International Fire Code 906.2 |
| Fire extinguisher is not obstructed | International Fire Code 906.6 |
| Fire extinguisher top does not exceed 5 feet from floor as mounted | International Fire Code 906.9 |
| Hood extinguishing system clean and inspected every six months | International Fire Code 904.11.6.4 |
| Class K extinguisher installed within 30 feet of hood system | International Fire Code 904.11.5 |
| Fire alarm system in proper working order, tested annually and records kept | International Fire code 901.6 |
| Sprinkler system shall be maintained and tested annually | International Fire Code 901.6 |

C. Appliance/Mechanical Devices

All appliances are properly connected and vented

D. Miscellaneous

| | |
|------------------------------------------------------------|-------------------------------|
| Address numbers shall be posted & minimum of 3 inches tall | International Fire Code 505.1 |
| Knox Box key to be current | International Fire Code 506.2 |

E. Electrical

| | |
|-----------------------------------------------------------------|-------------------------------|
| No extension cords used in place of permanent wiring | International Fire Code 605.1 |
| No missing/broken electrical cover plate | International Fire Code 605.1 |
| There are no spliced or frayed wires | International Fire Code 605.1 |
| No open gaps in electrical panel | International Fire Code 605.1 |
| Electrical panel is not obstructed | International Fire Code 605.1 |
| No multi-plug adapters in use, other than approved power strips | International Fire Code 605.1 |

F. Storage/Combustible Material/Housekeeping

| | |
|----------------------------------------------------------------------------------------------|----------------------------------|
| Flammable liquid properly stored | International Fire Code 313.1 |
| Compressed gas cylinders secured or have caps on the cylinders | International Fire Code 3003.3.3 |
| No combustible material stored near ignition source | International Fire Code 305.1 |
| No propane used/stored in building | International Fire Code 3809.9 |
| No storage shall be kept in exit stairways | International Fire Code 315.2.2 |
| Fire and Smoke walls shall be maintained & have no openings other than those allowed by code | International Fire Code 703.1 |
| 10 foot area around building free of combustible material | International Fire Code 315.3 |
| Maintain clear and visible access to and around fire department connection | International Fire Code 508.5.4 |

Moody Fire & Rescue will begin fire inspections over the next several months, and we hope by distributing this information it will educate business and building owners of what we will be inspecting. This is not a complete list in its entirety, but it does cover a large portion of what we will be inspecting. It is our goal to work with building and business owners to ensure all structures in the City of Moody are safe for all those that enter the building. If there are any questions pertaining to inspections or concerns with life safety in you building, please call or email Captain Barry Wright.

Cell: 205-571-1641

Email: swright@moodyalabama.gov

Regards,

Barry Wright

Barry Wright